

# Installation Instructions CUH-VB Mounting Bracket

Reference  
J101

- Contents :-
- bracket rails (2)
  - fixing studs (4)
  - nuts (12)
  - plain washers(8)

## LOCATION

These mounting brackets allow fixing of CUH Unit Heaters to ceiling for a vertical airflow. The air intakes to the rear, top and sides of the heater must not be restricted in any way.

Minimum allowable spacing between sides of heater and adjacent wall,  
CUH 03 and 05 - 300mm. CUH 07 to 20 - 600mm.

Minimum allowable spacing between sides and top of heater to adjacent ceiling, CUH 03 and 05 - 300mm.

## FIXING

Securely fix bracket rails to ceiling or structure at desired height and location

- refer to table for min / max dimensions and weights.

The brackets are easiest to install with the heater mounting holes outermost, thus allowing tightening of the locknuts. They can be mounted the other way if this allows a more secure fixing.

CUH 03 and 05 - The bracket rails can be mounted to the unit either horizontally or vertically with fixing hole centres 334mm or 253mm respectively.

CUH 07 and 10 - The bracket rails should be mounted horizontally with fixing hole centres 458mm.

## ASSEMBLY

Assemble mounting studs, nuts and spring washers to the four threaded inserts in rear of heater ensuring the studs do not protrude more than 10mm inside the case. Tighten nut against heater. Run second nuts approx 25mm down studs, put on plain washers. Locate studs in holes in bracket rails and secure with plain washers, spring washers and nuts. Adjust nuts to squarely locate heater without distorting the heater body. Ensure all nuts are tight and fixings secure.

## CONNECTION

Electrical connection should be made with reference to the installation instructions supplied with the heater.

Heater Cat No	Minimum Mounting Height (m)	Maximum Mounting Height (m) Vertical	Heater Weight (kgs)
CUH-03-1	2.2	2.8	12
CUH-03-3C	2.2	2.8	12
CUH-05-1	2.2	2.8	12
CUH-05-3C	2.2	2.8	12
CUH-07-3C	2.2	3.7	23
CUH-10-3C	2.2	4.3	23
CUH-15-3C	2.2	6.1	30
CUH-20-3C	2.2	5.5	30

Please keep these instructions for future reference.

The manufacturers reserve the right to change the specification at any time without prior notice E&OE



Commercial Electric Heat Limited  
Unit 712  
Thorp Arch Trading Estate  
WETHERBY  
West Yorkshire  
LS23 7BJ

Tel 01937 844994 Fax 01937 844123